


CITY OF MOUNTAIN VIEW MOUNTAIN VIEW, CALIFORNIA  
94042



Department

Public Works  
Waste Water Division  
Industrial Wastes Sampling

Date: March 28, 1980

Siltec  
405 National Avenue  
Mountain View, California 94043

Attention:

Gentlemen:

---- SEWAGE VIOLATION NOTICE ----

A sample of the liquid industrial waste being discharged into the City of Mountain View's sewer system by your operations on March 25, 1980 at 2:45 P. M. showed a pH value of 13.00.

Any such acid concentration can seriously interfere with waste treatment processes at the sewage treatment plant and could give cause for the liability for the expense of re-establishing bacteriological processes.

Section 35.32.10 of the City Code has set acceptable limits for pH between 5.5 and 10.0 with a value of 7.0 being considered neutral. In view of the seriousness of this type violation, it is requested that corrective action be taken immediately.

When required by the Director of Public Works, measurements, tests and analyses of the characteristics of wastes shall be made at the expense of the discharger. You may be requested to pay for an analysis at any time that the quality of your industrial wastes is known or suspected to be in violation of the provision of City Code Section 35.32.

Sincerely,

CITY OF MOUNTAIN VIEW

*Bill King*  
BILL KING

Acting Wastewater Superintendent